

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2589

Dated: 6/6/2024

It is certified that an inspection team headed by Md. Jubair (Executive Engineer).....

(Name of Officers with designation) from Public Health Division, Saharsa.....PHED

inspected the Shanti Mission Academy, Bariahi Bazar, Saharsa.....

(Name & Address of the school) on 05/06/2024.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Zero..... dated 6/06/2024.....

of District Lab. Saharsa..... (PHED Lab) certified that the

Shanti Mission Academy, Bariahi Bazar, Saharsa (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Three Month.....

Signature with Seal: *Md. Zubair* / 06/06/24.....

Name : Md. Zubair.....

Designation : Executive Engineer.....

Name & Address of the Office / Department :

To

The Principal.....

Shanti Mission Academy, Bariahi Bazar, Saharsa

(Name & Address of the Institution)

P.H. Division, Saharsa

Executive Engineer

P.H. Division, Saharsa

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Bihar.
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL) SAHARSA.
Public Health Engineering Department.
DRINKING WATER QUALITY TEST REPORT.

Name of District:- Saharsa

Sampling Date:-04.06.2024

Name of Person/Organization:-Shanti Mission Academy,Bariahi,Saharsa

Sample Collected By:- Shanti Mission Academy

Date Of Testing: 06.06.2024

Block:-Kahra

Panchyat: - Bariahi

SL. No.	Block	Type Of Source	Parameters											Report handed over to beneficiary or not	Remarks
			pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	F		
1	Kahra	Treated Water	6.51	0.3	204	132	70	24	12	18	80	0.2	0.314	Yes	
Desirable Limit*			6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	1.0	-	-
Permissible Limit* in absence of alternate source			NR	5.0	-	2000	600	200	100	1000	600	NR	1.5	-	-

Note: (i) Drinking Water Specification Second Revision -IS:10500:2012., (ii) BDL means Below Detection Limit., (iii) NR means no relaxation.

AK
06/06/24

Chemist

P.H Division Sitamarhi

M.H. Zubair
06/06/24

Executive Engineer
P.H Division, Saharsa